


**NOTES:**

1. NO PERMANENT STRUCTURES SHALL BE ALLOWED WITHIN 5 FEET.
2. TYPICAL INSTALLATION MAY BE MODIFIED AT THE DISCRETION OF HCWA.
3. MINIMUM OF 4 TEST COCKS.



HENRY COUNTY WATER AUTHORITY

**REDUCED PRESSURE  
ZONE DETAIL**

REVISED: 08/08/2016

SCALE: N.T.S.

DETAIL NO.

**W25**